



Product Service

Attestation of Conformity

No. N8A 18 05 95688 239

Holder of Certificate: LEDVANCE GmbHSteinerne Furt 62
86167 Augsburg
GERMANY**Product:** Recessed luminaires
(Recessed luminaires with LEDs)**Model(s):** SP SQUARE DK ADJ 8W/3000K,
SP MULTI 1X30W/3000K, SP MULTI 1X30W/4000K,
SP MULTI 2X30W/3000K, SP MULTI 2X30W/4000K,
SP MULTI 3X30W/3000K, SP MULTI 3X30W/4000K**Parameters:**

Rated Voltage:	See page 2
Rated Frequency:	See page 2
Rated Power:	See page 2
Protection Class:	See page 2
Degree of Protection:	IP20
Blue light risk group:	RG1
Ta:	45°C

Tested according to: EN 60598-2-2:2012
EN 60598-1:2015
EN 62493:2015

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 64142180129601**Date,** 2018-06-29
(Richard Xu)

After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

Page 1 of 2



Product Service

Attestation of Conformity

No. N8A 18 05 95688 239

Model	Rated voltage	Rated power(W)	CCT	Protection Class
SP SQUARE DK ADJ 8W/3000K	220-240V~ 50/60Hz for driver 25-42VDC for luminaires	8	3000K	Class II for driver Class III for luminaires
SP MULTI 1X30W/3000K	220-240V~ 50/60Hz for driver 27-42VDC for luminaires	30	3000K	
SP MULTI 1X30W/4000K			4000K	
SP MULTI 2X30W/3000K		2 x 30	3000K	
SP MULTI 2X30W/4000K			4000K	
SP MULTI 3X30W/3000K		3 x 30	3000K	
SP MULTI 3X30W/4000K			4000K	

Test report no.: 64142180129601

Date, 2018-06-29

CERTIFICATE

No. U6 18 05 95688 238



Product Service

Holder of Certificate: LEDVANCE GmbH

Steinerne Furt 62
86167 Augsburg
GERMANY

**Production
Facility(ies):**

88622

Certification Mark:



Product:

**Recessed luminaires
(Recessed luminaires with LEDs)**

Model(s):

SP SQUARE DK ADJ 8W/3000K,
SP MULTI 1X30W/3000K, SP MULTI 1X30W/4000K,
SP MULTI 2X30W/3000K, SP MULTI 2X30W/4000K,
SP MULTI 3X30W/3000K, SP MULTI 3X30W/4000K

Parameters:

Rated Voltage:	See page 2
Rated Frequency:	See page 2
Rated Power:	See page 2
Protection Class:	See page 2
Degree of Protection:	IP20
Blue light risk group:	RG1
Ta:	45°C

**Tested
according to:**

EN 60598-2-2:2012
EN 60598-1:2015

The product was voluntarily tested according to the listed standards. The product can be marked with the certification mark shown above. The certification mark must not be altered in any way. See also notes overleaf.

Test report no.:

64142180129601

Date, 2018-06-29


(Richard Xu)

Page 1 of 2





Product Service

C E R T I F I C A T E

No. U6 18 05 95688 238

Model	Rated voltage	Rated power(W)	CCT	Protection Class
SP SQUARE DK ADJ 8W/3000K	220-240V~ 50/60Hz for driver 25-42VDC for luminaires	8	3000K	Class II for driver Class III for luminaires
SP MULTI 1X30W/3000K	220-240V~ 50/60Hz for driver 27-42VDC for luminaires	30	3000K	
SP MULTI 1X30W/4000K			4000K	
SP MULTI 2X30W/3000K		2 x 30	3000K	
SP MULTI 2X30W/4000K			4000K	
SP MULTI 3X30W/3000K		3 x 30	3000K	
SP MULTI 3X30W/4000K			4000K	

Test report no.: 64142180129601

Date, 2018-06-29

Page 2 of 2