

## **Declaration of conformity**

NO. OF PAGES

1 (1)

We: nVent HOFFMAN
Po de la Finca 1, Ed
3 Madrid 28223

Declare under our sole responsibility that the standard powder paint coating for mild steel product ranges:

MCS, MCD, MCF, MCI, MKS, MKD, MAS, MAD, MAP, STB

to which this declaration relates, has been successfully tested according to:

## ISO 6270 Paints and varnishes – Determination of resistance to humidity – Part 2: Condensation

Acceptance criteria: after 240 hours, blistering 0(S0) to ISO 4628-2 and rusting Ri0 to ISO 4628-3.

## ISO 9227 Corrosion tests in artificial atmospheres - Salt spray tests

Acceptance criteria: after 480 hours, corrosion creep ≤ 2 mm from scribe.

These results match the test procedure for corrosivity category C4-M in standard ISO 12944, which are:

240 hours condensation test to ISO 6270

480 hours salt spray test to ISO 9227

Madrid, 13th March 2019

Juan Pablo Rincon, Product Manager